

# **Users Guide for Odors** Removed by Austin HealthMate<sup>™</sup> Products

**SPACE** 



**INDEX** 

## **KEY**







Above

Average



High

Low Average

Locations A contain the lowest amount of odor and D the highest; B and C represent levels in between. Many of the classifications are rather general, so it was necessary to pick a typical or average condition. The odor index for a specific situation could vary somewhat from that given in the table if special circumstances apply.


SPACE	INDEX	SPACE	INDEX
Adhesive manufacturing		Bomb shelters	
plants	C	Book stacks	В
Air conditioning systems	C	Breweries	C
Aircraft	C	Buses	B
Airline terminals	В	Bus terminals	В
Air raid shelters	D		_
Amusement parks	В	Cafeterias	В
Animal rooms	D	Canneries	В
Apartment buildings	Α	Central air conditioning	
Apartments	Α	systems	C
Apple storage	C	Chemical laboratories	D D D
Art studios	В	Chemical plants	D
Athletic clubs	C	Chemical storage	D
Atomic processes	D	Chlorine manufacture	D
Auditoriums	В	Churches	Α
Automobiles	C	Circulating fans	В
	_	Circulating systems	В
Banks	B	Clinics	С
Bank counting rooms	C	Closets	В
Bank safe deposit	_	Club houses	С
departments	C	Coating processes	D
Bank vaults	D	Cocktail lounges	B C B C D C
Banquet rooms	D C C	Cold storage plants	C
Barber shops	C	Collective protection	_
Bars	C	shelters	D
Basements	C	Commercial establishments	; <u>B</u>
Bathrooms	В	Conference rooms	С
Beauty shops	C	Conventions	C
Bedrooms	Α	Corridors	B C B C
Binderies	В	Creameries	C
Biological processes	D	Crowded rooms	C

Dairies Darkrooms Decalcomania production Department stores Dentists' offices Dining rooms Display parlors Distilleries Doctors' offices Drafting rooms Dressing rooms Drug stores Dry cleaning plants	C C B B C C B B C C
Educational institutions Electrical installations Elevators Embalming rooms Enclosed spaces Engine rooms Equipment rooms Examination rooms Exhaust hoods	B B C C C B C
Factories Federal offices Fermentation plants Fertilizer plants Fish markets Five-and-ten-cent stores Food processing Forced air furnaces Fruit storages Funeral homes	C B C C C C
Game rooms Garbage disposal plants Gravity return furnaces Greenhouses Grocery stores Grills	C D A B C
Homes Hospital rooms Hospitals Hotels Hotel rooms	A C C B

SPACE	INDEX	SPACE	INDEX	SPACE	INDEX
Incinerators	C	Penal institutions	C	Silverware manufacture	В
Individual cubicals	C	Personnel protection	C	Soap manufacture	C
Industrial kitchens	C	Pet shops	C	Soda fountains	В
Industrial offices	В	Pharmaceutical plants	C	Specialty shops	C
Institutions	В	Photo dark rooms	C	State institutions	В
Instrument rooms	В	Photographic industry	C	Steamships	В
		Photographic studios	C B	Stock rooms	В
Jewelry stores	В	Planes	В	Storage spaces	В
160		Plastics manufacturing	C	Stores	В
Kitchens	C	Plating shops	C	Studios	C
Kitchen exhausts	D	Pollution control	D	Stuffy Rooms	В
Labaratarias		Poultry processing	C	Super Markets	В
Laboratories Laundries	D	Poultry sales rooms	CCC	Surgical Rooms	C B
	C D	Prescription departments	C	Switchboard Rooms	D
Leather processing Libraries	В	Printing plants Private offices	В	Tannarias	C
Linoleum plants	D	Processing laboratories		Tanneries Tar Processing	
Live poultry rooms	C	Processing rooms	C	Taverns	C
Living rooms	A	Projection booths	D	Telephone Booths	D C C
Lobbies	B	Public assembly rooms	C	Telephone Exchanges	C
Locker rooms	C	Public buildings	C B	Television Studios	C
Lounges	В	Public toilets	C	Test Cubicles	C
Lunch counters	C	Pulp and paper plants	D	Theaters	C B
Lunch rooms	C	Taip and paper plante		Theater lobbies	C
Editori roomo		Radio studios	e	Theater lounges	C
Maintenance departments	В	Railway cars	C	Ticket booths	C B
Manufacturing plants	C	Railway stations	В	Toilets	C
Mausoleums	Č	Reading rooms	В	Trains	C B
Meat packing plants	D	Reception rooms	В	Train reservation offices	В
Meat markets	C	Recovery room, hospital	C	Train recervation emises	
Meat storage	С	Recreation halls	C	Undertakers	C
Metal industries	В	Recreation rooms	C	Unit air coolers	В
Military equipment	C	Refineries	C	Untidy rooms, hospital	C
Military installations	В	Refrigerated showcases	C	Unventilated spaces	C
Mixed cold storage	C	Rendering plants	D C	·	
Morgues	C	Refrigerators	C	Varnish manufacture	D
Motels	В	Research buildings	C	Vegetable storage	C
Motion picture studios	C	Reservation offices	C	Vest systems	D C
Municipal offices	В	Residences	Α	Vestibules	C
Museums	В	Resin manufacturing	D	Veterinary hospitals	C
		Restrooms	В		
New processes	D	Restaurants	В	Waiting rooms	В
Night clubs	C	Restaurant kitchens	C	Wards, hospital	C
Nuclear processes	D	Retail shops	A	Warehouses	В
Nurseries	В	Rubber plants	D B	Waste treatment plants	D B
O dan la anciana		Rumpus rooms	В	Window ventilators	B
Odor barriers	C	Calaa waanaa		Wood working plants	В
Offices	В	Sales rooms	В	Work rooms	C
Office buildings Officers' clubs	C	Sample rooms Schools	В	V Day darkrooms	
Oilcloth production		Service departments	C	X-Ray darkrooms	C
Operating rooms	D C	Sewage disposal plants	C	Yachts	В
Operating rooms		Sewer vents		Youth clubs	C
Paint departments	D	Show cases	D C C	TOULT CIUDS	C
Paint plants	C	Sick rooms	C	Zoological gardens	C
r anti pianto	C	Olok Toomis	U	Zoological gardens	C



Capacity Index for Gases, Vapors and **Fumes Removed** by Austin HealthMate™ **Products** 



The number given represents typical or average conditions and might vary in specific instances. The values in the table have been assembled from many sources including laboratory tests and field experience.

## The capacity index has the following meaning:



Capacity

High capacity for all materials in this category One pound takes up about 20% to 50% of its own weight - average about 1/3 (33-1/3%). This category includes most of the odor causing substances.



Capacity

Satisfactory capacity for all items in this category. These constitute good applications but the capacity is not as high as for category 4. Absorbs about 10 to 25% of its weight - average about 1/6 (16.7%).



Capacity

Includes substances which are not highly absorbed but which might be taken up sufficiently to give good service under the particular conditions of operation. These require individual checking.



Adsorption capacity is low for these materials. Activated carbon cannot be satisfactorily used to remove them under normal circumstances.

## **SUBSTANCE INDEX** Acetaldehyde Acetic acid Acetic anhydrite Acetone \* Acetylene Acrolein Acrylic acid Aerylonitrile Adhesives Air-Wick Alcoholic beverages Amines Ammonia Amyl acetate Amyl alcohol Amyl ether Animal odors Anesthetics Aniline Antiseptics Asphalt fumes Automobile exhaust Bathroom smells Benzene Bleaching solutions Body odors Bromine Burned flesh Burned food Burning fat Butadiene Butane Butanone Butyl acetate Butyl alcohol Butyl cellosolve Butyl chloride Butyl ether Butylene Butyne Butyraldehyde Butyric acid Camphor Cancer odor

SUBSTANCE	INDEX
Charred materials Cheese	4
* Chlorine	3
Chlorobenzene	4
Chlorobutadiene	4
Chloroform Chloronitropropane	4
Chloropicrin	4
Cigarette smoke odor	3 4 4 4 4 4 4 3 3 3 4 4 4 4 4 4 4 4 4 4
Citrus and other fruits	4
Cleaning compounds Coal smoke odor	4
Combustion odors	3
Cooking odors	4
* Corrosive gases	3
Creosote Cresol	4
Crotonaldehyde	4
Cyclohexane	4
Cyclohexanol	4
Cyclohexanone Cyclohexene	4
Dead animals	4
Decane	4
Decaying substances	4
Deodorants Detergents	4
Dibromoethane	4
Dichlorobenzene	4
Dichlorodifluoromethar	ne 4
Dichloroethane Dichloroethylene	4
Dichloroethyl ether	4
Dichloromonoflourmet	hane 3
Dichloronitroethane	4
Dichloropropane Dichlorotetrafluoroetha	4
Diesel fumes	4
Diethylamine	3
Diethyl ketone	
Dimethylaniline	4
Dimethylsulfide Dioxane	4
Dipropyl ketone	4
Disinfectants	4
Embalming odors	4
Epoxy Ethane	4 4 4 4 4 4 1 3 4 4
Ether	3
Ethyl acetate	4
Ethyl acrylate	4
Ethyl alcohol	4

Caprylic acid

Carbolic acid Carbon disulfide

Cellosolve

Carbon dioxide

Carbon monoxide

Cellosolve acetate

Carbon tetrachloride

<sup>\*</sup>Straight activated carbon does not have much capacity for some reactive gases, such as ammonia, formaldehyde, etc. In some cases where the gas is chemically reactive, appropriate impregnated activated carbon can be recommended. Substances marked with an asterisk fall into this category.

SUBSTANCE	INDEX	SUBSTANCE	INDEX	SUBSTANCE	INDEX
* Ethyl amine	3	Menthol	4	Pitch	4
Ethyl benzene	4	Mercaptans	4	Plastics	4
Ethyl bromide	4	Mesityl oxide	4	Poison gases	3
Ethyl chloride	3	Methane	1	Pollen	3
Ethyl ether	3	Methyl acetate	3	Popcorn and candy	4
Ethyl formate	3	Methyl acrylate	4	Poultry odors	4
Ethyl mercaptan	3	Methyl alcohol	3 3 4	Propane	2
Ethyl silicate	4	Methyl bromide	3	* Propionaldehyde	3
* Ethylene	1	Methyl butyl ketone	4	Propionic acid	4
Ethylene chlorohydrin	4	Methyl cellosolve	4	Propyl acetate	4
Ethylene dichloride	4	Methyl cellosolve acetate	4	Propyl alcohol	4
Ethylene oxide	3	Methyl chloride	3	Propyl chloride	4
Essential oils	4	Methyl chloroform	4	Propyl ether	4
Eucalyptole	4	Methyl ether	3	Propyl mercaptan	4
Exhaust fumes	3	Methyl ethyl ketone	4	* Propylene	2
Fertilizer	4	Methyl formate	3 2	* Propyne	2
Film processing odors	3	Methyl iodine	2	Putrefying substances	3
Fish odors	4	Methyl isobutyl ketone	4	Putrescine	4
Floral scents	4	Methyl mercaptan	4	Pyridine	4
Fluorotrichloromethane	3	Methylcyclohexane	4	Radiation products	2
Food aromas	4	Methylcyclohexanol	4	Rancid oils	4
* Formaldehyde	2	Methylcyclohexanone	4	Resins	4
* Formic acid	3 2	Methylene chloride Mildew	3	Reodorants	4
Fuel gases Fumes	3			Ripening fruits	4
	4	Mixed odors Mold	3	Rubber	4
Gangrene Garlic	4	Molochlorobenzene		Sauerkraut	4
Gasoline	4	Moth balls	4	Sewer odors	4
Glues	4	Mustard gas	4	Skatole	3
Heptane	4	Naphtha (coal tar)	4	Slaughtering odors Smog	4
Heptylene	4	Naphtha (coartar)	4	Soaps	4
Hexane	3	Naphthalene	4	Smoke	4
* Hexylene	3	Nicotine	4	Solvents	3 3 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4
* Hexyne	3	* Nitric acid	3	Sour milks	4
Hospital odors	4	Nitro benzenes	4	Spilled beverages	4
Household smells	4	Nitroethane	4	Spoiled food stuffs	4
Hydrogen	1	* Nitrogen dioxide	2	Stale odors	4
* Hydrogen bromide	3	Nitroglycerine	4	Stoddard solvent	4
* Hydrogen chloride	2	Nitromethane	4	Stuffiness	4
<ul> <li>Hydrogen cyanide</li> </ul>	3	Nitropropane	4	Styrene monomer	4
<ul> <li>Hydrogen fluoride</li> </ul>	2	Nitrotoluene	4	* Sulfur dioxide	2
<ul> <li>Hydrogen iodide</li> </ul>	3 2	Nonane	4	* Sulfer trioxide	3 4 4 3 4 4
<ul> <li>Hydrogen selenide</li> </ul>	2	Noxious gases	3	Sulfuric acid	4
<ul> <li>Hydrogen sulfide</li> </ul>	3	Octalene	4	Tar	4
Incense	4	Octane	4	<ul> <li>Tarnishing gases</li> </ul>	3
Indole	4	Odorants	4	Tear gas	4
Industrial wastes	3	Onions	4	Tetrachloroethane	
Ink odors	4	Organic chemicals	4	Tetrachloroethylene	4
lodine	4	Ozone	4	Theatrical makeup odors	4
Idoform	4	Packing house odors	4	Tobacco smoke odor	4
Irritants	4	Paint and redecorating odors Palmitic acid		Toilet odors	4
Isophorone	4		4	Toluene	4
* Isoprene	3	Paper deteriorations	4	Toluidine	4
Isopropyl acetate	4	Paradichlorbenzene	4	Trichloroethylene	4
Isopropyl alcohol Isopropyl ether	4	Paste and glue PCBs	4	Trichloroethane	4
Kerosene	4	Pentane	3	Turpentine Urea	4
Kitchen odors	7	Pentanone	4		4
Lactic acid	$\frac{1}{A}$	* Pentylene		Uric acid Valeric acid	4
Lingering odors	$\frac{1}{4}$	* Pentyne	3	Valeric acid Valericaldehyde	4
Liquid fuels	$\frac{1}{4}$	Perchloroethylene	4	Varnish fumes	4
Liquor odors	4	Perfumes, cosmetics	4	Varnisir furnes Vinegar	4
Lubricating oils and grease	s 4	Perspirations	4	Vinegal Vinyl chloride	3
Lysol	4	Persistent odors	4	Volatile materials	3
Masking agents	4	Pet odors	4	Waste products	4
Medicinal odors	4	Phenol		Wood alcohol	4 4 4 4 4 4 4 4 4 4 4 4 3 3 3 4
Melons	4	Phosgene	3	Xylene	4
		-		-	